

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7259-1491:107

Page 1 of 1

**CATEGORY:** Air Sampling Smoke Detector

**LISTEE:** Vision Systems Inc., 35 Pond Park Rd., Hingham MA 02043  
Contact: \*Wes Marcks (781) 740-2223 FAX (781) 740-4433

**DESIGN:** Models VESDA Laser Compact VLC-505 (VN) and VLC-500 (RO) air sampling smoke detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 18-30 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as air sampling smoke detection system for use with separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation.

\*Rev. 06-18-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**